

Certificate of Compliance



Intertek

This is a certificate of conformity to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment of their Factory Production Control and are subject to continuing annual assessments of their continued Factory Production Control compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed in the accompanying schedule.

You have been awarded:

Intertek Warnock Hersey Mark for Fire resistant doors and door sets

Standards: BS 476 Part 22 (1987)

Certificate number: WH116 – 26876203

Organization: Intermetal LLC

P.O. Box 474039
Dubai Investment Park 1
Dubai, United Arab Emirates

Product: Intermetal 60 Fire Double door Assembly Rating: 60 minutes (Insulation & Integrity)

Maximum sizes:

Latched single acting, Double leaf doorset without vision panel. 54mm thickness wooden door for use in masonry or concrete wall configurations.
Overall Size of doorset (Double): 1972 x 2195mm (w x h)

Check Listing report ref. 37023 for full details
Check Test reports ref. CFR1509301 for details

Certification body: Intertek Testing Services NA, Inc.

Initial registration: March 1st, 2016

Date of expiry: February 28th, 2017

Issue status: 1

Dustin Behling
Certification Coordination Manager
Name


Signature

03/01/2016
Date